

August 1, 2008

International Materials Inc.
117½ - 54th Street
Newport Beach, CA 92663

Attention: Mr. Carleton Elliott

Dear Sir:

Re: Alofts Project, Phoenix, AZ – 2-Hour Sure-Board® Wall Assemblies


Intertek has reviewed the enclosed wall assembly designs and confirm that the addition of Sure-Board® Series 200 as described will not affect the original 2-hour fire resistance rating of the assembly.

Our fire testing of Sure-Board® Series 200 clearly showed an increase in fire resistance and hose stream performance in gypsum wallboard wall assemblies.

I trust this is the information required.

Yours truly,

INTERTEK TESTING SERVICES NA LTD.




Michael van Geyn, A.Sc.T.
Senior Engineer, Engineering Services

MVG/bjm

Encl. (3 pages)

Re: Alofts Project, Phoenix, AZ - 2-Hour Sure-Board® Wall Assemblies



Re: Aloftis Project, Phoenix, AZ - 2-Hour Sure-Board® Wall Assemblies

