



NYC Department of Buildings
280 Broadway, New York, NY 10007

Patricia Lancaster, FAIA, Commissioner

Siun Derkhidam
Assistant Mechanical Engineer

Materials and Equipment Acceptance Division
Phone: (212) 566-3271
Fax: (212) 566-3840
E-mail: siund@buildings.nyc.gov

July 5, 2007

Mr. Carleton Elliott
Intermat Inc.
2045 Placentia Avenue
Costa Mesa, CA 92627

Dear Mr. Elliott:

Enclosed is a final official signed copy of MEA acceptance of your product, **MEA 216-07-M**, which you may use as proof of your product acceptance in New York City.

This document, together with proper labeling and installation in accordance with New York City Building Code, will enable the inspector to know that the product(s) installed is/are legal.

All shipments and deliveries of accepted materials to the job site are required to be labeled or tagged in accordance with the format below:

Accepted For Use City of New York Department of Buildings MEA 216-07-M Company Name

Sincerely,

A handwritten signature in cursive script that reads "Siun Derkhidam".

Siun Derkhidam

c: Deborah F. Taylor, AIA, LEED AP
Executive Director, Special Projects and MEA

safety · service · integrity



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 216-07-M

Manufacturer: Internat Inc., 2045 Placentia Avenue, Costa Mesa, CA 92627

Trade Name(s): Sure-Board®, MagBoard

Product: 22-gauge steel sheet laminated to various forms of exterior substrate

Pertinent Code Section(s): 27-335.1

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Hardwood/Plywood & Veneer Association Laboratory and Testing Service (HPVA); Anderson Labs, Inc.

Test Report(s): HPVA T-12170 dated February 6, 2007
Anderson Labs, Inc. #659 dated March 19, 2007

Description: Sure-Board® panel is a 22-gauge steel sheet laminated to any form of exterior-type gypsum, concrete board, glassmat, fiber-reinforced gypsum or magnesium board. Sheet panels are used to resist wind and seismic lateral loads. It may also be used to prevent penetration from airborne debris, as well as impact and security protection for buildings.

Flame Spread Rating - 5
Smoke Developed Rating - 5

Terms and Conditions: The above-described panel is accepted with the following conditions:

1. Material may be used in either new or existing noncombustible construction Group I or combustible Group II buildings.
2. Installation shall be in accordance with Section 27-335.1 and manufacturer's supplied instructions.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 5, 2007

Examined By Simon Derbinder